

LICENCE CERTIFICATE

for TÜV Rheinland Conformity Mark

No. 968/V 1217.01/21

Licence Holder:

Vastas Valf Armatur Sanayi Ticaret A.S. Organize Sanayi Bolgesi, 2. Caddesi No: 22 Cerkezkov 59500 Tekirdag Turkey

Manufacturer / Manufacturing Plant:

same as licence holder

Date of Application:

File Ref.:

Date of Issue:

2021-04-21

968/V 1217.01/21

2021-06-10

Conformity Mark:



SIL/PL Capability

www.tuv.com

The holder of this Licence Certificate is authorized to affix the TÜV Rheinland Conformity Mark shown on this page on products that correspond to the certified product described below and to use it in print and electronic media for information and advertising purposes for the certified product. All provisions of the currently valid Regulation for Certification and Conformity Mark Regulation must be observed.

The validity for use of the Conformity Mark is dependent on the existence of a valid certificate for the certified product.

Link for download:

http://fs-products.tuvasi.com/tm/3705

Annual Fee Units for Use of the Conformity Mark:

Units of Fee: 10

Certified Product, Identification of the Device:

Kind of Product:

Gate Valves

Type Designation:

E500 (2" - 72") Bolted Bonnet Wedge Gate Valve E50B (4" - 72") Through Conduit Slab Gate Valve

E50D (4" - 72") Through Conduit Expanding Gate Valve

E50W (2" - 24") Pressure Seal Bonnet Welded End Wedge Gate Valve E50F (2" - 24") Pressure Seal Bonnet Flanged End Wedge Gate Valve

Technical Doc.:

Safety Manual "VA-SM-E5-21R0"	0	2021-04-27
Drawing of Gate E500 "BOM-E500"	00	2018-12-14
Drawing of Gate E53B "BOM-E53B"	00	2013-12-25
Drawing of Gate E56D "BOM-E56D"	02	2015-10-05
Drawing of Gate E56W <i>"E56WG.5Ax"</i>	00	2017-10-06
Drawing of Gate E55F "BOM-E55F"	02	2018-10-03

Special Remarks:

Report-No. 968/V 1217.01/21 dated 2021-06-08 and

Certificate No.: 968/V 1217.01/21 dated 2021-06-10

TÜV Rheinland Industrie Service GmbH Bereich Automation **Funktionale Sicherheit**

2021-06-10 Date

Am Grauen Stein, 51105 Köln Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. (FH) Wolf Rückwart





SIL /PL Capability

www.tuv.com ID 0600000000

No.: 968/V 1217.01/21

Product tested

Gate Valves

Certificate holder

Vastas Valf Armatur Sanayi

Ticaret A.S.

Organize Sanayi Bolgesi, 2.

Caddesi No: 22

Cerkezkoy 59500 Tekirdag

Turkey

Type designation

E500 (2" - 72") Bolted Bonnet Wedge Gate Valve E50B (4" - 72") Through Conduit Slab Gate Valve E50D (4" - 72") Through Conduit Expanding Gate Valve

E50W (2" - 24") Pressure Seal Bonnet Welded End Wedge Gate Valve E50F (2" - 24") Pressure Seal Bonnet Flanged End Wedge Gate Valve

Codes and standards

IEC 61508 Parts 1-2 and 4-7:2010

Intended application

Safety Functions:

- Closing on demand and keeping up the external tightness - Opening on demand and keeping up the external tightness

The gate valves are suitable for use in a safety instrumented system up to SIL 2.

Under consideration of the minimum required hardware fault tolerance HFT = 1 the valves may be used in a redundant structure up to SIL 3.

Specific requirements

The instructions of the associated Installation, Operating and Safety Manual shall

be considered.

Summary of test results see back side of this certificate.

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP1 V1.0:2017 in its actual version, whose results are documented in Report No. 968/V 1217.01/21 dated 2021-06-08. This certificate is valid only for products, which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH

Bereich Automation Funktionale Sicherheit

Am Grauen Stein, 51105 Köln

Köln, 2021-06-10

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. (FH) Wolf Rückwart

Fax: +49 221 806-1539, E-Mail: industrie-service@de tuv.com Rheinland Industrie Service GmbH, Am Grauen Stein, 51105 Köln / Germany Tel: +49 221 806-1790, <u></u>2

TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval

0/201 10,17 E A4

www.fs-products.com



968/V 1217.01/21 - page 2

Holder: Vastas Valf Armatur Sanayi Ticaret A.S.

Organize Sanayi Bölgesi Sabanci Caddesi No. 22

Cerkezköy / Tekirdag

Turkey

Product tested: Gate-Valves of type

E500 (2" - 72") - Bolted Bonnet Wedge Gate Valve

E50B (4" - 72") - Through Conduit Slab Gate

Valve

E50D (4" - 72") - Through Conduit Expanding

Gate Valve

E50W (2" - 24") - Pressure Seal Bonnet Welded

End Wedge Gate Valve

E50F (2" - 24") - Pressure Seal Bonnet Flanged

End Wedge Gate Valve

Results of Assessment

Route of Assessment		2 _H / 1 _S
Type of Sub-system		Type A
Mode of Operation		Low Demand Mode
Hardware Fault Tolerance	HFT	0
Systematic Capability		SC 3

Closing on demand and keeping up the external tightness

Dangerous Failure Rate	λ _D	2.09 E-07 / h	209 FIT
Average Probability of Failure on Demand 1oo1	PFD _{avg} (T ₁)	9.30 E-04	
Average Probability of Failure on Demand 1oo2	PFD _{avg} (T ₁)	9.40 E-05	

Opening on demand and keeping up the external tightness

Dangerous Failure Rate	λ _D	2.02 E-07 / h 202	FIT
Average Probability of Failure on Demand 1oo1	PFD _{avg} (T ₁)	8.99 E-04	
Average Probability of Failure on Demand 1oo2	PFD _{avg} (T ₁)	9.08 E-05	

Assumptions for the calculations above: DC = 0 %, T_1 = 1 year, MRT = 72 h, β_{1002} = 10 %

Origin of failure rates

The stated failure rates for low demand are the result of an FMEDA with tailored failure rates for the design and manufacturing process.

Furthermore the results have been verified by field-feedback data.

Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing.

The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.